
SUBMITTAL DATA SHEET

NL Service Fitting - 74764-22

-22 CTS Compression x -22 CTS Compression x FNPT





| MODEL NO. | SIZE | Α | В | С | D |
|-----------|-------------|------|------|-------|-------|
| 74764-22 | 3/4 | 3.12 | 1.61 | 3/4 | 3/4 |
| 74764-22 | 3/4 X 1 | 3.76 | 1.84 | 3/4 | 1 |
| 74764-22 | 1 X 3/4 | 3.56 | 1.75 | 1 | 3/4 |
| 74764-22 | 1 | 3.52 | 1.76 | 1 | 1 |
| 74764-22 | 1 X 1 1/4 | 4.36 | 2.25 | 1 | 1 1/4 |
| 74764-22 | 1 X 1 1/2 | 4.36 | 2.25 | 1 | 1 1/2 |
| 74764-22 | 1 1/4 | 4.20 | 2.18 | 1 1/4 | 1 1/4 |
| 74764-22 | 1 1/4 X 3/4 | 4.54 | 2.06 | 1 1/4 | 3/4 |
| 74764-22 | 1 1/4 X 1 | 4.54 | 2.06 | 1 1/4 | 1 |
| 74764-22 | 1 1/2 X 3/4 | 4.54 | 2.06 | 1 1/2 | 3/4 |
| 74764-22 | 1 1/2 X 1 | 4.54 | 2.06 | 1 1/2 | 1 |
| 74764-22 | 1 1/2 | 4.24 | 2.17 | 1 1/2 | 1 1/2 |
| 74764-22 | 2 X 3/4 | 4.00 | 2.34 | 2 | 3/4 |
| 74764-22 | 2 X 1 | 4.00 | 2.34 | 2 | 1 |
| 74764-22 | 2 | 5.02 | 2.57 | 2 | 2 |

SUBMITTAL INFORMATION

- Manufactured in compliance with ANSI/AWWA C800 (latest revision)
- Brass components in contact with potable water conform to ASTM B584, UNS C89833 (latest revision) and identified with "NL"
- Certified to NSF/ANSI 61 and NSF/ANSI 372
- Brass components not in contact with potable water conform to ASTM B62 and ASTM B584, UNS C83600 -85-5-5-5 (latest revision)
- Large wrench flats provided for proper installation
- Insert stiffeners required on all flexible plastic connections



A.Y. McDonald Mfg. Co.

P.O. Box 508

Dubuque, IA 52004-508

Toll Free: 1-800-292-2737 Fax: 1-800-832-9296

Hours: 7:00 a.m. - 5:00 p.m., CST

sales@aymcdonald.com www.aymcdonald.com

A.Y. McDonald considers the information on this assembly drawing correct when published. Item and option availability, including specifications, are subject to change without notice.

Submitted by: 10-20